APAVE SUDEUROPE SAS
LABORATOIRE DE LYON TASSIN
Accredited body by COFRAC n° 1-1461
Essais Sur Produits
177, route de Sain-Bel

69160 TASSIN LA DEMI-LUNE

ERICO
B.P 31
Rue Charles Dallière
42161 ANDREZIEUX BOUTHEON

SYNTHESIS DOCUMENT
CONFORMITY ASSESSMENT

1 SCOPE OF THIS DOCUMENT

The present document constitutes the synthesis of the APAVE report n° 6943931-001-1 which gives the details of inspections and tests achieved on the range of product.

2 CONCERNED PRODUCT

- Name : Range of insulators
- Designation : /
- Make : ERICO
- Model : ERIFLEX ISO-TP

SPECIFIED FEATURE

- Voltage : 500Vac or 1000Vac / 500Vdc or 1500Vdc
- Neutral position : all
- Serial number : /

3 SCOPE OF THE MISSION (to see details in report)

Conformity Assessment of the range of product and its technical file to the following documents :

⇒ NF EN 61439-1 – March 2012

CONCLUSION OF THE REPORT

The conclusion of the report shows that the examined product is in compliance with the prescriptions of the reference documents.

Tassin the 2017/11/13

The Technical Manager of Testing laboratory

Document original immatériel



Limit of validity of this document : 5 years

Xavier SCHMITT

This document is not a report established under the title of a Notified body, it is a synthesis of the mission achieved by APAVE and only the complete French report maybe used as reference. It doesn't substitute itself to the DECLARATION OF CONFORMITY issued by the manufacturer, according the market regulation of the EUROPEAN UNION and cannot be use as a guarantee of the production conformity to the type.
Its reproduction is only allowed as a complete photographic facsimile

APAVE SUDEUROPE SAS
LABORATOIRE DE LYON TASSIN
Organisme accrédité par le COFRAC sous le n° 1-1461
Essais Sur Produits
177, route de Sain-Bel
69160 TASSIN LA DEMI-LUNE

ERICO
B.P. 31
Rue Charles Dallière
42161 ANDREZIEUX BOUTHEON

DOCUMENT DE SYNTHESE
EVALUATION DE CONFORMITE

1. PORTEE DE CE DOCUMENT

Le présent document constitue la synthèse du rapport APAVE n° 6943931-001-1 du 07/06/2013 qui donne le détail des résultats des contrôles et essais réalisés sur la gamme de produit.

2. PRODUIT CONCERNE CARACTERISTIQUES SPECIFIEES

- Dénomination : Gammes d'isolateurs
- Désignation : /
- Marque/type : ERICO
- Modèle : ERIFLEX ISO-TP
- Tension : 500 Vac ou 1000 Vac / 500 Vdc ou 1500 Vdc
- Régime de neutre : tous
- Numéro de série : /

3. OBJECTIF DE LA MISSION (la portée est décrite dans notre rapport)

Évaluation de la conformité de la gamme de produit et de son dossier technique aux documents suivants :

⇒ NF EN 61439-1 – Edition Mars 2012

4. CONCLUSION DU RAPPORT

La conclusion du rapport montre que le produit examiné est conforme aux prescriptions du (des) document(s) de référence.

Fait à Tassin le : 13/11/2017

Le responsable du laboratoire
Essais sur Produits

Document original immatériel

Limite de validité de ce document : 5 ans

Xavier SCHMITT

Ce document n'est pas un rapport établi au titre d'un Organisme Notifié, il est une synthèse de la mission réalisée par l'APAVE et seul le rapport complet peut-être utilisé comme référence. Il ne se substitue pas à la déclaration de conformité que le constructeur doit établir pour la mise sur le marché de l'UNION EUROPEENNE et ne peut pas être utilisé comme moyen de garantie de la conformité au type de l'ensemble de la production.
Sa reproduction n'est autorisée que sous la forme de fac-similé photographique intégral.