# Certificate of Compliance

**Certificate:** 1645435 **Master Contract:** 154112 (018677_0_000)

**Project:** 70117123 **Date Issued:** 2017-02-01

**Issued to:** **Wago-Kontakttechnik GmbH & Co. KG**
**Hansastrasse 27**
**Minden/Westfalen, 32423**
**GERMANY**

**Attention: Gregor Willemsen**

***The products listed below are eligible to bear the CSA Mark shown***

Issued by: Jan Ritzo Holtman
*Jan Ritzo Holtman*

**PRODUCTS**

CLASS - C622801 - WIRE CONNECTING DEVICES-Terminal Assemblies

Terminal Block Assemblies with spring force connection, for DIN-rail mounting, for stranded and solid insulated copper conductors: Series 2004.

**Certificate:** 1645435 **Master Contract:** 154112

**Project:** 70117123 **Date Issued:** 2017-02-01

| Catalogue number | Voltage [V] | Group | Current [A] | Wire Range [AWG] | Strip Length [mm] | Remarks |
|---|---|---|---|---|---|---|
| 2004-1201 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1202 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1203 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1204 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1205 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1206 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1207 | - | - | - | 20-10 | 11-13 | PCTB |
| 2004-1208 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1209 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1301 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1302 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1303 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1304 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1305 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1306 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1307 | - | - | - | 20-10 | 11-13 | PCTB |
| 2004-1308 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1309 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1401 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1402 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1403 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1404 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1405 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1406 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1407 | - | - | - | 20-10 | 11-13 | PCTB |
| 2004-1408 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-1409 | 600 | B,C | 30 | 20-10 | 11-13 | |
| 2004-501 | 300 | B,C | 30 | 20-10 | 11-13 | Test plug without spacer |
| 2004-501 | 600 | B,C | 30 | 20-10 | 11-13 | Test plug with spacer 2004-549 between poles |
| 2004-549 | - | - | - | - | - | Spacer for test plug |

Notes:
1. Certified as a component for use only where the suitability of the final combination is determined by CSA Group or another NRTL
2. Catalogue numbers may be completed with suffixes to denote color, number of poles and other mechanical variations not affecting the relevant properties.
3. The suitability of accessories like end-plates, end-stops, strain-relief plates, locking levers, etc. shall be determined in the final combination.

## APPLICABLE REQUIREMENTS

CSA C22.2 No. 0 - General Requirements Canadian Electrical Code, Part II
CSA C22.2 No. 158 - Terminal Blocks

# *Supplement to Certificate of Compliance*

**Certificate:** 1645435 **Master Contract:** 154112 (018677_0_000)

***The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.***

## Product Certification History

| Project | Date | Description |
|---|---|---|
| 70117123 | 2017-02-01 | Update without test to report 154112-1645435 series 2004 change mounting feet housing |
| 70013470 | March 18, 2015 | The file was updated from CSA C22.2 No. 158-M1987 to CSA C22.2 No. 158-10. |
| 2043219 | July 21, 2008 | Update to report 1645435 to cover addition of alternate colored types 2004-1205, -1305, -1405. |
| 1790696 | May 11, 2006 | Update to cover certification of Test plug type 2004-501 and spacer type 2004-549. |
| 1645435 | March 7, 2005 | CSA original certification of terminal blocks Types 2004-12.., 2004-13.., 2004-14.. |